

# Efnissamþykkt

---

Umsögn Umhverfisstofnunar á því hvort efni/byggingarvara uppfylli skilyrði Svansins til að vera notuð í hús sem stefnir að umhverfissvottun í þessu tilfelli vegna verkefnisins um Miðbæ Selfoss

**Nafn á efni, byggingarefni eða vöru:**

**Jentro axial press fitting system**

**Notkunarsvið:**

Rör og tengistykki fyrir neysluvatns og hitakerfi.

## Fylgiskjöl

**Viðaukar**

- Viðauki 6: Declaration on emissions of formaldehyde
- Viðauki 7: Declaration from the manufacturer of chemical product
- Viðauki 9: Declaration on substances excluded from construction products, construction goods and material
- Viðauki 10: Declaration on nanoparticles and antibacterial additives in goods
- Viðauki 11: Windows and exterior doors
- Viðauki 12: Declaration of tree species not permitted to be used in Nordic Ecolabelled buildings

**Önnur skjöl**

JENTRO PEX brochure: upplýsingabæklingur.

**Athugasemdir eða afgreiðsla UST**

Plaströrin eru samþykkt, kopar tengi falla fyrir utan viðmiðanna.

Dags: 07.04.2020

Fyrir hönd Svansins: Guðrún Lilja Kristinsdóttir