



DECISION ON CERTIFICATION

number *B/MI-004/2013-020-0*

Product heat meter

Type US-1, US-2, US-3, US-4, US-5

Manufacturer BAYLAN Ölçü Aletleri San. Ve Ticaret Ltd. Şti.
Atatürk Organize San. Bölgesi 10046 Sokak No: 14
Çigli / Izmir, Turkey

Applicant manufacturer

Application No B 17/2013/MI-004

Final protocol No 013/1432/13 MI-004

Product classification

heat meter according to Annex MI-004 of the Directive 2004/22/EC of the European Parliament and of the Council of 31 March 2004 on measuring instruments (MID) as later amended.

Standards and regulations used by certification

Governmental Ordinance of the Slovak Republic No. 294/2005 Coll.
(which implements the Directive 2004/22/EC as later amended)
OIML R 75-1 2002, OIML R 75-2 2002
EN 1434-1: 2007, EN 1434-4: 2007
WELMEC 8.14, WELMEC 11.1, WELMEC 11.3, WELMEC 7.2

Certification procedure 1b

Summary of evaluation

On the basis of tests, measurements, investigations, assessments and evaluations results, the Final protocol was worked out, upon which the conformity of product performances with the technical requirements stated in regulations and recommendations given above was found

Decision on certification

approve

reject

Date of issue

2013-03-20

Decision approved by

Ing. Stefan Kral, PhD.
representative of notified body



V súlade s

nariadením vlády Slovenskej republiky č. 294/2005 Z. z. o meradlách v znení nariadenia vlády č. 445/2010 Z. z., ktorým sa transponuje smernica Európskeho parlamentu a Rady 2004/22/ES z 31. marca 2004 o meradlách v platnom znení do právneho poriadku Slovenskej republiky

In accordance with

Government Ordinance of the Slovak Republic No 294/2005 Coll. on measuring instruments as amended by Government Ordinance No 445/2010 Coll., which implements, in the Slovakia, the Directive 2004/22/EC of the European Parliament and of the Council of 31 March 2004 on measuring instruments as later amended

Žiadateľ

Issued to (applicant)

BAYLAN Ölçü Aletleri San. Ve Ticaret Ltd. Şti.
Atatürk Organize San. Bölgesi 10046 Sokak No: 14
Çiğli / Izmir, Turkey

Druh meradla

In respect of

Obchodná značka/Typ
Trade mark/Type

merač tepla

heat meter

US-1, US-2, US-3, US-4, US-5

Základné požiadavky

Essential requirements

príloha č. 1 a príloha MI-004 k nariadeniu vlády SR č. 294/2005 Z. z.
Annex No 1 and Annex MI-004 to SR Government Ordinance No 294/2005 Coll.

Použité harmon. normy
a normat. dokumenty
Harmonised standards and
normative documents used

OIML R 75-1 2002
OIML R 75-2 2002
EN 1434-1: 2007
EN 1434-4: 2007

Ďalšie použité dokumenty
Further applied documents

WELMEC 8.14
WELMEC 11.1
WELMEC 11.3
WELMEC 7.2

Popis a dokumentácia

Description and
documentation

Základné parametre, popis meradla a podmienky schválenia sú uvedené v záverečnom protokole číslo 013/1432/13 MI-004, ktorý je súčasťou tohto ES certifikátu typu. Všetky výkresy, diagramy a dokumentácia sú archivované v zložke označenej Baylan_US-..._0.

The principal characteristics, instrument description and approval conditions are set out in the Final protocol No 013/1432/13 MI-004, which is part of this EC - type examination certificate. All the designs, schematic diagrams and documentation are recorded in reference folder Baylan_US-..._0.

Notifikovaná osoba
Notified Body

1432

Platný do
Valid until

2023-03-20

Vystavený dňa
Date of issue

2013-03-20



Ing. Štefan Král, PhD.
zástupca notifikovanej osoby
Representative of Notified Body

Ak sa na meradlo vzťahujú aj ďalšie technické predpisy, ktoré zahŕňajú iné aspekty meradla, ES certifikát typu platí len za predpokladu zhody meradla s týmito predpismi.

Where the instrument is subject to other Directives covering other aspects, this EC - type examination certificate is valid, assuming that the instrument conforms to the provisions of those Directives.



Date: 20.03.2013

Number of pages: 13

FINAL PROTOCOL

No. 013/1432/13 MI-004

Product: heat meter

Type: *US-1, US-2, US-3, US-4, US-5*

Manufacturer BAYLAN Ölçü Aletleri San. Ve Tic. Ltd. Şti.
Atatürk Organize San. Bölgesi 10046 Sokak No: 14
Çiğli / Izmir, Turkey

Applicant: BAYLAN Ölçü Aletleri San. Ve Tic. Ltd. Şti.
Atatürk Organize San. Bölgesi 10046 Sokak No: 14
Çiğli / Izmir, Turkey

Application No.: 2013/MI-004/B017

Assignment No.: 2013/MI-004/B017

Certification scheme: 1b

Distribution list: SKTC – 177 (NB 1432)
Applicant

Final Protocol may be reproduced or published only in full and upon written permission of the authorised/notified body SKTC-177 (NB 1432).



1 General provision

This Final Protocol shall be used as an evidence for the authorised body SKTC-177 (notified body 1432), Hviezdoslavova 31, 974 01 Banská Bystrica, Slovakia, authorising it to issue Decision on certification and EC - type examination certificate in accordance with § 11, Art. 10 of Law No 264/1999 Coll. on technical requirements on products and on conformity assessment and on amendments and supplements of some acts, in compliance with the Government Ordinance of the Slovak Republic No 294/2005 Coll. on measuring instruments (hereinafter referred to as „Government Ordinance“) as amended by Government Ordinance of the Slovak Republic No 445/2010 Coll. for product type:

heat meter
type *US-1, US-2, US-3, US-4, US-5*

1.1 Product description

1.1.1 Characteristics

The ultrasonic heat meters series *US-...* are compact measuring instrument intended for metering of energy consumption in heating systems (exchange circuits) filled with water as heat conveying liquid. The complete heat meter consists of ultrasonic flow sensor, pair of temperature sensors and heat meter calculator. Flow sensor may be installed into the horizontal or vertical pipe lines. All installation requirements are described in User Guide issued by BAYLAN company.

For installation is required:

- a distance of minimum 25 cm between signal cables and other installations,
- min. 10xDN length of straight pipe before the meter, and min. 5xDN length of straight pipe after the meter (DN is the diameter of meter).

For external view of measuring instrument see figures 1, for installation see figure 2 and for main dimensions see figure 3 in Annex 1.



The meaning of signs in the type marking and order codes is as follows:

BAYLAN US DNxx - Px - Cxx

Type Number

Meter size

DN15: $q_p = 1,5 \text{ m}^3/\text{h}$, G3/4", PN16

DN20: $q_p = 2,5 \text{ m}^3/\text{h}$, G1", PN16

DN25: $q_p = 3,5 \text{ m}^3/\text{h}$, G1 1/4", PN16

DN32: $q_p = 6,0 \text{ m}^3/\text{h}$, G1 1/2", PN16

DN40: $q_p = 10 \text{ m}^3/\text{h}$, G2", PN16

Power supply

P6: 6 years battery life

P11: 11 years battery life

Communication

C01: Wired M-Bus

C02: Pulse output

C03: 4~20mA DC linear output

C12: Wired M-Bus and Pulse output

C13: Wired M-Bus and 4~20mA DC linear output

C23: Pulse output and 4~20mA DC linear output

1.1.2 Principle of operation

Quantity of heat is determined by measurement of flow rate (q) and temperature difference $\Delta\theta = \theta_m - \theta_{out}$, between the inlet θ_m (flow temperature) and outlet θ_{out} (return temperature) of the heat exchange circuit. Flow and return temperatures are measured by a pair of resistance temperature sensors with Pt1000 elements on the base of resistance measured. Signals from temperature and flow sensors are transmitted to electronic calculator, which evaluates (calculates) and indicates the quantity of heat exchanged.

1.1.3 Essential parts

- ultrasonic flow sensor;
- pair of temperature sensors;
- heat meter calculator.



1.1.3.1 Flow sensor

Ultrasonic flow sensor of type *US-1*, *US-2*, *US-3*, *US-4*, *US-5* (manufacturer *BAYLAN*, Turkey) consist of brass housing with installed ultrasound transducers. The flow sensors $q_p = (1,5 - 10) \text{ m}^3/\text{h}$ have intended place for temperature sensor.

The velocity of flow is measured by using the principle of ultrasound. It can measure the average velocity along the path of an emitted beam of ultrasound by averaging the difference in measured transit time between the pulses of ultrasound propagating into and against the direction of the flow. The flow measurement is based on an acoustic wave time of flight principle. The flow meter body is equipped with 2 ultrasonic transducers facing 2 acoustic reflectors.

Flow sensors									
Type	DN (mm)	Flow Rate (m ³ /h)			q _v /q _p	Dimensions (mm)			Connection
		q ₁	q ₂	q ₃		Length	Width	Height	
<i>US-1</i>	15	0,03	1,5	3,0	1:50	110	110	96	G3/4"
<i>US-2</i>	20	0,05	2,5	5,0		13	110	105	G1"
<i>US-3</i>	25	0,07	3,5	7,0		160	110	114	G1 1/2"
<i>US-4</i>	32	0,12	6,0	12,0		180	110	120	G1 1/2"
<i>US-5</i>	40	0,2	10	20		200	110	130	G2"
Accuracy class								2	
Pressure Loss ΔP (at q_p)								$\leq 25 \text{ kPa}$	
PS/PN								1,6 MPa	
Max admissible temperature								95 °C	
Nominal meter factor								100L/pulse	

1.1.3.2 Temperature sensors

Platinum resistance temperature sensors *Pt 1000*, manufacturer *JUMO*, of type *902475/50/1500*, in accordance with EN 60751:2008 in two-wire configuration installed onto flow pipe (red sign marked sensor) and in the return pipe (blue sign marked sensor). The standard length of the cable is 1,5 m.

The temperature sensor set shall have identical performance in temperature measurement.

It is designed for use with the energy calculator for measurement of the temperature of flow medium in a district heating net.

Temperature sensor	
Manufacturer / Type	<i>JUMO 902475/50/1500</i>
Temperature range	0-105 °C
Temperature differenc range	3-105 K
Temperature resolution	0,01 °C
Length of cable	1,5 m
diameter	5 mm
Response time for temperature sensor	2s with 50% temperature varies

Detailed temperature sensors data, values of parameters etc. may be found in Technical specification listed in section 2.3.1.

1.1.3.3 Calculator

The calculator of type *US-1, US-2, US-3, US-4, US-5* (manufacturer *BAYLAN*, Turkey) receives and evaluates signals from the attached flow and temperature sensors. The calculator calculates a quantity of heat taking into account the flow, the temperature difference measurements between the flow and return sides of the heat exchanger circuit and thermal coefficients in compliance with EN 1434-1:2007. It is also the control, display and data store unit for the meter. The real-time circuit providing the control unit with the actual date and time is permanently backed-up. Metrology relevant measured and calculated values are indicated on the 8-digits LCD display. Measured values and computed results are recorded and stored in the permanent memory. The integrated function of the calculator ensures storage and review of relevant data for 18 months. Accumulated flow and heat consumption are logged once per hour.

The detailed descriptions and operation of the calculator, block and connections schemes, wiring diagrams and values of parameters may be found in manufacturer's documentations.

Blok scheme of calculator see on Fig. 5.

Calculator	
Manufacturer	BAYLAN
Maximum value of thermal power	DN15 : 225, DN20: 376, DN25: 526, DN32: 900, DN40: 1500
Type	<i>US-1, US-2, US-3, US-4, US-5</i>
Environmental class	A
Electromagnetic class	E1
Mechanical class	M1
Limits of temperature	0 to 100 °C
Limits of temperature difference	3 to 70 K
Display unit options	kWh, MWh, GJ
Dynamic behaviour	Measure flow rate 4 times per second and measure temperature 1 times per four second
Physical dimensions	Length: 110 mm, Width: 80 mm, Height: 51 mm
Battery power supply requirements	Point 1.1.5

1.1.3.4 Display

Back illumination LCD display including 8-digits, measuring units and information field

- Display unit options kWh, MWh, GJ
- Cumulated Heat Energy 0,1 kWh-9999999,9 kWh
- Volume 0,01 m³
- Instant Heat Power 0,1 kW
- Temperature 0,01°C
- Time to LCD off (sleep mode) 10 min.



1.1.4 Alternative parts

- M-Bus interface (standard communication protocol),
- Pulse output (optional);
- Analog output 4~20mA DC (Optional)
- IrDA (optical interface).

The above mentioned alternative parts are outside the scope of Annex MI-004 of MID. No legally relevant data can be altered via communication interfaces and modems. Data. Data transferred via these alternative parts are not considered as a metrological relevant data.

1.1.5 Non-essential parts

- one 3,6V lithium battery for calculator, model ER18505 (4000 mAh, life ≥ 6 years);
- two 3,6V lithium battery for calculator, model ER17505 (3600 mAh each, life ≥ 11 years);
- 24V DC – external supply for special version (optional)
- Non-return valve (if required).

1.1.6 Essential functions

- measurement and displaying of the volume of accumulated water in m^3 ;
- measurement and displaying of the flow and return temperatures;
- calculation and displaying of temperature difference;
- calculation of accumulated energy in kWh or GJ.
- measurement of instant flow rate in m^3/h ;
- operation time in years or days or hours;
- display date, time;
- display record of last 18 months

1.1.7 Non-essential functions

- display segment test;
- display software version number;
- display meter ID, software ID, type ID, M-bus address;
- display meter type;
- display various faults.

The detailed descriptions and operation of the heat meter, block and connections schemes, wiring diagrams and values of parameters may be found in documentations listed in section 2.3.1.



1.2 Principal technical and metrological data

Parameter	Symbol	Unit	Value
Accuracy class	-	-	2
Limits of temperature	θ_{min}	°C	4
	θ_{max}	°C	95
Limits of temperature difference	$\Delta\theta_{min}$	K	3
	$\Delta\theta_{max}$	K	70
Nominal diameter (connections)	DN	mm	15; 20; 25; 32; 40
Body thread/Connection thread	-	-	DN15 – G 3/4" DN20 – G1" DN25 – G1 1/2" DN32 – G1 1/2" DN40 – G2"
Permanent flow rate	q_p	m ³ /h	DN15 – 1,5 DN20 – 2,5 DN25 – 3,5 DN32 – 6 DN40 – 10
Maximum flow rate	q_s	m ³ /h	DN15 – 3,0 DN20 – 5,0 DN25 – 7,0 DN32 – 12,0 DN40 – 20,0
Minimum flow rate	q_l	m ³ /h	DN15 – 0,03 DN20 – 0,05 DN25 – 0,07 DN32 – 0,12 DN40 – 0,2
Low flow threshold value	DN15 DN20 DN25	m ³ /h	0,02
	DN32 DN40		0,03
Maximum admissible working pressure	P_{max}	bar	16
Maximum thermal power	P_s	kW	DN15 – 225 DN20 – 376 DN25 – 526 DN32 – 900 DN40 – 1500
Pulse Output	-	-	100 L/impulse
Installation position	-	-	H/V
Installation place	-	-	flow
Protection degree	-	-	IP65
Climatic class	-	°C	+ 5 to + 55
Environmental class	-	-	A
Mechanical class	-	-	M1

Electromagnetic class	-	-	E1
Heat medium	-	-	water
Indicating device	-	-	LCD 8 digits
Units displayed	-	-	kWh, MWh, GJ, °C, m ³ /h, L, gal.
Resolution of LCD		kWh MWh GJ m ³	99 999 99,9 99 999,999 999 999,99 999 999,99
Software version	-	DN15 DN20 DN25 DN32 DN40	BYL US1 BYL US2 BYL US3 BYL US4 BYL US5
Checksum/ CRC16 Algorithm	-	DN15 DN20 DN25 DN32 DN40	0x8B3A 0x5B8D 0xc1d0 0x7E0A A6AC

Software: BYL US1 (can be shown in the display). A CRC check digit is calculated for the entire software including the metrology and application parts.

User can operate to check information on LCD of the meter by pressing the button on top cover, including temperature, flow rate, energy, meter type, software version, etc.

1.3 Technical and metrological requirements

- construction, technical and metrological parameters of the heat meter shall comply with the documentation presented within the process of type certification;
- all the characteristics of the measuring instrument (including those not mentioned) shall meet the respective requirements of Government ordinance.

1.4 Marking and inscriptions

The following data shall be marked on the heat meter:

- a) manufacturer's name or mark;
- b) type of heat meter (US-...);
- c) year of manufacture and serial number;
- d) accuracy class (2);
- e) limits of flow rate (q_i , q_p , q_s);
- f) limits of temperature (θ_{min} , θ_{max});
- g) limits of temperature difference ($\Delta\theta_{min}$, $\Delta\theta_{max}$);
- h) place of the flow sensor installation (flow);
- i) indication of the direction of flow;

- j) maximum admissible working pressure, PS in bar
- k) nominal pressure, PN
- l) environmental class (A);
- m) mechanical class (M1);
- n) electromagnetic class (E1);
- o) EC-type examination certificate number (SK 13 – 020 MI-004);
- p) conformity mark according to § 7 of Government ordinance on measuring instruments (CE marking with supplementary metrology marking).

The flow direction shall be marked on a flow sensor body in form of an arrow. Any inscriptions on the heat meter and relevant information on the LCD display shall be in the EC official language; the international abbreviations are admitted. The heat meter inscriptions and marking shall comply with the requirement of Article 9, Annex 1 to Government ordinance.

1.5 Recommendations for the final product testing and verification

It is recommended to perform the final product testing (module D) or verification (module F) of the heat meter's compliance with the technical requirements in line with OIML R 75-2 2002 or with EN 1434-5: 2007. The metrological examination should be carried out according to 7.6 of mentioned Recommendation at least at the following three temperature differences ($\Delta\theta$) and flow rates (q):

Technical requirements in line with OIML R 75-2 2002

- a) $\Delta\theta_{min} \leq \Delta\theta \leq 1,2 \Delta\theta_{min}$ and $0,9 q_p \leq q \leq q_p$
- b) $10 K \leq \Delta\theta \leq 20 K$ and $0,2 q_p \leq q \leq 0,22 q_p$
- c) $\Delta\theta_{max} - 5 K \leq \Delta\theta \leq \Delta\theta_{max}$ and $q_i \leq q \leq 1,1 q_i$

Technical requirements in line with EN 1434-5: 2007

- a) $\Delta\theta_{min} \leq \Delta\theta \leq 1,2 \Delta\theta_{min}$ and $0,9 q_p \leq q \leq q_p$
- b) $10 K \leq \Delta\theta \leq 20 K$ and $0,1 q_p \leq q \leq 0,11 q_p$
- c) $\Delta\theta_{max} - 5 K \leq \Delta\theta \leq \Delta\theta_{max}$ and $q_i \leq q \leq 1,1 q_i$

At any of the specified temperature differences and flow rates the error (of indication) shall not exceed the maximum permissible error.

Upon the request of the notified body carrying out the verification (in case of module F only), the applicant applying for the heat meter conformity assessment shall submit declaration on conformity to the certified type and the operation instruction in EC official language.



1.6 Security measures

The heat meter shall be protected against unauthorised manipulation by the sealing marks which secure (see Fig. 8) connections:

- | | |
|--|-------------|
| a) flow temperature sensor | 1 x |
| b) return temperature sensor | 1 x |
| c) calculator box | 1 x |
| d) flow sensor body against dismantling..... | 1 x sticker |

1.7 Validity period of verification

The validity period of verification is generally specified by legislation of the country where the heat meter is used.

1.8 Information on product samples

The following tests were carried out:

Metrological tests according to OIML R75-2 on

- 2 samples of heat meters type *US-1* serial numbers 13010085 and 13010004;
- 2 samples of heat meters type *US-2* serial numbers 13010033 and 13010025;
- 2 samples of heat meters type *US-5* serial numbers 13010043 and 13010045;

EMC test

- 1 sample of heat meter type *US-3* serial number 4000021;

IP protection test

- 1 sample of heat meter type *US-2* serial number 4000006.

Upon the tests completion, the samples were returned back to the manufacturer. Type examination was carried out in manner Art.2 (a) of Annex B, to the Government ordinance.

2 Test procedures and findings

2.1 Scope of assessment

The product conformity assessment was performed in accordance with § 12 Art. 3 b) of Act No 264/1999 Coll. and in accordance with Government ordinance No 294/2005 Coll. as amended by Government Ordinance of the Slovak Republic No 445/2010 Coll. The product was evaluated in terms of the technical requirements on heat meters, in line with Annexes 1 and MI-004 to Government ordinance.



2.2 Place and way of tests and measurement performance, assessment and evaluation

The conformity assessment was carried out in SKTC-177 (NB 1432) based on the presented documentation and on results contained in the test reports, as specified in the point 2.3. Examination of heat meter samples was carried in accordance with the harmonised standard EN 1434-1:2007 and/or International recommendation OIML R 75-2 2002 in testing laboratories of:

- Manufacturers testing laboratory (BAYLAN, Izmir, Turkey) witnessed by SASTEK A.Ş., Ankara, Turkey – metrological tests;
- TESTCOM Praha laboratories department of CMI, Czech republic – EMC tests;
- ESIM testing laboratory – IP protection tests, Ankara, Turkey;
- SLM CV Banská Bystrica – software evaluation.

2.3 Documentation submitted and used for assessment purposes

2.3.1 Technical documents

- Technical specifications for BAYLAN Ultrasonic Heat meter (35 pages) issued by manufacturer;
- Ultrasonic User Guide for US-... Ultrasonic heat meter (16 pages) issued by manufacturer;
- Component list (1 page);
- Datasheet of temperature sensor pair PT1000 of type 902475/20/1500 issued by manufacturer of sensor (JUMO);
- Software review (set of documents from manufacturer);
- Meter software explanation issued by manufacturer;
- Drawing no. EC-579 "US-... Exploded View" of 26.06.2012 (1 page);
- Drawing no. EC-577 "US-... Meter View" (1 page) 26.06.2012of;
- Drawing no. EC-578 "US-... Detailed View" of 26.06.2012 (1 page);
- Drawing no. EC-580 "US-... Sealing Plan" of 26.06.2012 (1 page);
- Drawing no. EC-573 "US-... PCB scheme of 01.03.2013 (1 page);
- Drawing no. S-413 "Baylan US-1 Heat meter marking" of 26.06.2012 (1 page);
- Drawing no. S-414 "Baylan US-2 Heat meter marking" of 26.06.2012 (1 page);
- Drawing no. S-415 "Baylan US-3 Heat meter marking" of 26.06.2012 (1 page);
- Drawing no. S-416 "Baylan US-5 Heat meter marking" of 26.06.2012 (1 page);
- Drawing no. S-4173 "Baylan US-1 Heat meter marking" of 26.06.2012 (1 page);
- Drawings no. EC-574 "Baylan US-... LCD" of 01.03.2013 (4 pages);



2.3.2 Submitted documents

- Test and Inspection Report No. HM/04-13 of 04.03.2013 (metrological tests of heat meter type *US-1* according to OIML R 75-2), issued by SASTEK. A.Ş., Ankara (29 pages);
- Test and Inspection Report No. HM/05-13 of 04.03.2013 (metrological tests of heat meter type *US-3* according to OIML R 75-2), issued by SASTEK. A.Ş., Ankara (29 pages);
- Test and Inspection Report No. HM/06-13 of 06.03.2013 (metrological tests of heat meter type *US-5* according to OIML R 75-2), issued by SASTEK. A.Ş., Ankara (29 pages);
- EMC Test report No 8551-PT-E0041-13 (1 page) with Annex 1 (36 pages) of 08.03.2013 issued by CMI, TESTCOM Praha EMC laboratory;
- Software test report No. 2013/MI-004/B017/SW08 of 19.03.2013 issued by SLM NB 1432;
- IP test report No. LVD-2013039 of 14.02.2013 issued by ESIM, Turkey (15 pages);
- Check list to type evaluation report No 2013/MI-004 /B017 related to ultrasonic heat meters series *US-.....* (references according to OIML R 75-1 and OIML R 75-2 of 22.03.2013).

2.3.3 Standards and regulations used

- SR Government ordinance No 294/2005 Coll. on measuring instruments as amended by Government Ordinance of the Slovak Republic No 445/2010 Coll.;
- OIML R 75-1 2002;
- OIML R-75-2 2002;
- EN 1434-1: 2007;
- EN 1434-4: 2007;
- WELMEC Guide 7.2., WELMEC Guide 11.3.

3 Test results

By assessment of the determined values of the products characteristics it was stated that the properties of the assessed type of product are in conformity with the provisions of the Slovak Government Ordinance No 294/2005 Coll. as amended by Government Ordinance of the Slovak Republic No 445/2010 Coll. and with requirements of the International recommendation OIML R 75-1 2002 and OIML R 75-2 2002 concerning the respective product.



4 Conclusion

It follows from the results of tests, measurements, findings and assessment as specified in this Protocol that the characteristics of the respective product type are in conformity with the provisions of the Slovak Government ordinance No 294/2005 Coll. as amended by Government Ordinance of the Slovak Republic No 445/2010 Coll. and with the requirements of International recommendation OIML R 75-1 2002 and OIML R 75-2 2002.

5 Annexes

Annex 1 – Figures

- Fig. 1: Illustrative view on heat meters series US-.... of BAYLAN company
- Fig. 2: Installation of heat meters series US-....
- Fig. 3: Main dimensions of heat meters series US-...
- Fig. 4: Display of heat meter type US-...
- Fig. 5: Block scheme of calculator
- Fig. 6: Explode view of heat meters series US-..
- Fig. 7: PIN assignment and dimension of heat meters series US-..
- Fig. 8: Sealing plan on heat meters series US-..
- Fig. 9: Name plate and marking of heat meter – sample of type US-2
- Fig. 10: Cross section of heat meters series US-...

Note:

The documentation specified in the points 2.3.1 and 2.3.2 and preserved by SLM – Products Certification Body is the integral part of the Final protocol.

Assessed by:

Ing. Mária Danková
Senior Officer of PCB

