



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8511BU0128

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	ISOTUBI S.L. C/Mecànica 6 Pol. Ind. Santa Rita, E-08755 Castellbisbal (Barcelona)
Distributor <i>Verteiler</i>	ISOTUBI S.L. C/Mecànica 6 Pol. Ind. Santa Rita, E-08755 Castellbisbal (Barcelona)
Product Category <i>Produktart</i>	Installation systems and system joints (PN 10): pipe joint for pipes in drinking water installation systems (8511)
Product description <i>Produktbezeichnung</i>	system joints designed as compressing joints made of stainless steel for pipes made of stainless steel according to DVGW-working sheet GW 541, Ø 12 - 168,3 mm, additional Ø 12 - 54 mm unpressed leaky
Model <i>Modell</i>	NUMEPRESS
Test reports <i>Prüfberichte</i>	Laboratory control test: 3864775 from 11.10.2023 (TSZ) Type testing: 600011059 from 28.12.2012 (TSZ) Type testing: 600011058 from 27.12.2012 (TSZ)
Test basis <i>Prüfgrundlagen</i>	DVGW W 534-(P) (01.07.2015) UBA BWGL-Metalle (11.01.2023) UBA ELASTOM (16.03.2016) DVGW W 270 (01.11.2007)

Date of Expiry / File No. 09.03.2029 / 24-0121-WNV
Ablaufdatum / Aktenzeichen

21.02.2024 LE A-1/2 J.A. O. Z.
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993
www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
NUMEPRESS	Diameter: 12,0 mm	
NUMEPRESS	Diameter: 15,0 mm	
NUMEPRESS	Diameter: 18,0 mm	
NUMEPRESS	Diameter: 22,0 mm	
NUMEPRESS	Diameter: 28,0 mm	
NUMEPRESS	Diameter: 35,0 mm	
NUMEPRESS	Diameter: 42,0 mm	
NUMEPRESS	Diameter: 54,0 mm	
NUMEPRESS	Diameter: 76,1 mm	
NUMEPRESS	Diameter: 88,9 mm	
NUMEPRESS	Diameter: 108,0 mm	
NUMEPRESS	Diameter: 114,3 mm	
NUMEPRESS	Diameter: 139,7 mm	
NUMEPRESS	Diameter: 168,3 mm	

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No. <i>Registr.-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
DW-5253BQ0461	Sealing material for drinking water installations	TIMO-70/TIMO-70	Tecnogomma International S.p.A.
DW-5253BQ0577	Sealing material for drinking water installations	01/U70 EP/01/U70 EP	LAV.EL GOMMA S.r.l.

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

The test was made with tubes made of stainless steel according to DVGW-working sheet GW 541.